

SLAB EDGE INSULATION (Interior Slab)

N1104.2.5 Below grade exterior insulation. Below grade exterior insulation shall meet the following conditions:

1. The insulation shall be a material that is approved for below-grade applications in wet environments.
2. Insulation shall be installed from the top of the footing to the top of the concrete basement wall.
3. Insulation shall be adequately protected from the elements (ultraviolet and mechanical) per manufacturer's specifications.
4. The top of the insulation shall be installed in a manner to allow water run-off and prevent pooling.



N1104.7 Slab-on-grade floors. For slab-on-grade floors, the perimeter of the floor shall be insulated.

The insulation shall extend downward from the top of the slab for a minimum of 24 inches (610 mm) or downward to the bottom of the slab, then horizontally beneath the slab for a minimum total distance of 24 inches (610 mm).



Exception: For monolithic slabs, the insulation shall extend downward from the top of the slab to the bottom of the thickened edge.

