



SHALLOW TRENCH SERVICE CONNECTION

NOTES:

1. PIPE AND FITTINGS SHALL BE COMPATIBLE. ONLY MANUFACTURED FITTINGS SHALL BE USED.
2. MINIMUM DEPTH AT RIGHT OF WAY OR EASEMENT LINE SHALL BE 4 FEET.
3. SERVICE CLEANOUT REQUIRED ON ALL NEW CONSTRUCTION. SEE STD DWG 00400-14.
4. TYPE OF TAPPING TEE SHALL BE WATERTIGHT AND CONFORM TO STANDARD SPECIFICATION REQUIREMENTS.
5. TAPPING TEE SHALL NOT PROTRUDE INTO THE SANITARY MAIN.
6. MARKER POSTS AND BLOCKING SHALL BE TREATED WOOD. POST SHALL BE 2x4 FIR. POST TO EXTEND 12" MINIMUM ABOVE FINISH GRADE AND EXPOSED AREA SHALL BE PAINTED GREEN.
7. FOR BEDDING AND BACKFILL SEE STD DWG 00400-01.



**CITY of LEBANON SUPPLEMENTAL DRAWING**

APPROVED

*Donald J. Hamrick*  
CITY ENGINEER

**SHALLOW TRENCH SERVICE CONNECTION**

DATE:  
Jan. 2009

DRAWING NO:  
00400-12