



NOTES:

1. PIPE AND FITTINGS SHALL BE COMPATIBLE. ONLY MANUFACTURED FITTINGS SHALL BE USED.
2. MINIMUM DEPTH AT RIGHT OF WAY OR EASEMENT LINE SHALL BE 4 FEET.
3. SERVICE CLEANOUT REQUIRED ON ALL NEW CONSTRUCTION. SEE STD DWGS. 00400-12 AND 00400-14.
4. TYPE OF TAPPING TEE SHALL BE WATERTIGHT AND CONFORM TO STANDARD SPECIFICATION REQUIREMENTS.
5. TAPPING TEE SHALL NOT PROTRUDE INTO THE SANITARY MAIN.
6. VERTICAL TRENCH WALLS ARE REQUIRED. IF IT IS NOT POSSIBLE TO MAINTAIN VERTICAL TRENCH WALLS, USE ALTERNATE CONNECTION METHOD TO MAINTAIN 6" MAXIMUM DISTANCE BETWEEN RISER PIPE AND TRENCH WALLS. REPLACE ALL EXCAVATED MATERIAL WITH FULL DEPTH GRANULAR BACKFILL COMPACTED TO 95% RELATIVE DENSITY.
7. FOR BEDDING AND BACKFILL SEE STD DWG 00400-01.



CITY of LEBANON SUPPLEMENTAL DRAWING

APPROVED

Domalf H. Alwan
CITY ENGINEER

**DEEP TRENCH
SERVICE
CONNECTION**

DATE:
Jan. 2009

DRAWING NO:
00400-13