



NOTES:

1. A COMBINATION AIR/VACUUM RELEASE VALVE MAY BE INSTALLED ONLY WITH APPROVAL OF THE CITY ENGINEER.
2. COMBINATION AIR/VACUUM RELEASE VALVES SHALL BE APCO SERIES 140 C OR APPROVED EQUAL.
3. ASSEMBLIES SHALL BE INSTALLED AT HIGH POINTS IN WATER LINE. BREATHER TUBE MUST EXTEND ABOVE FINISH GRADE LEVEL (AS SHOWN ABOVE), FACE DOWNWARDS AND BE FITTED WITH AN APPROVED BRASS INSECT SCREEN.
4. PIPE AND VALVE SIZES WILL BE SPECIFIED BY THE ENGINEER.



CITY of LEBANON SUPPLEMENTAL DRAWING	
APPROVED  CITY ENGINEER	COMBINATION AIR-RELEASE VALVE ASSY. (2" & SMALLER)
DATE: Jan. 2009	DRAWING NO: 01100-08