



Historical Water Sample Data		
Week of February 15, 2024, through February 21, 2024		
Finish Chlorine		
Min (> 0.20 mg/L)*	Max (< 4.00 mg/L)*	Average (~ 1.00 mg/L)*
0.75	1.30	0.97
Finish pH		
Min (> 7.00 pH)*	Max (< 9.00 pH)*	Average
7.54	7.82	7.70
Raw Water Turbidity		
Min	Max	Average
2	55	14
Finish Water Turbidity		
Min	Max (.100 NTU)*	Average
0.012	0.049	0.016

*** THESE NUMBERS REPRESENT OREGON HEALTH AUTHORITY GUIDELINES FOR SAMPLE REQUIREMENTS PER OREGON ADMINISTRATIVE RULES OAR 333-061-0335 AND OAR 333-061-0330 WHICH CAN BE FOUND [HERE](#)**

DEFINITIONS

- Finish Chlorine: Chlorine level of finished water being distributed
- Finish pH: pH level of finished water being distributed
- Finish Water Turbidity: Turbidity level of water being distributed
- pH: Power of hydrogen
- Raw Water Turbidity: Turbidity of untreated South Santiam River water pulled from water intake
- Turbidity: Cloudiness of the water