



Historical Water Sample Data
Week of March 7, 2024, through March 13, 2024

Finish Chlorine

Min (> 0.20 mg/L)*	Max (< 4.00 mg/L)*	Average (~ 1.00 mg/L)*
0.71	1.38	1.03

Finish pH

Min (> 7.00 pH)*	Max (< 9.00 pH)*	Average
7.66	8.18	7.88

Raw Water Turbidity

Min	Max	Average
2	32	8

Finish Water Turbidity

Min	Max (.100 NTU)*	Average
0.012	0.046	0.024

*** THESE NUMBERS REPRESENT OREGON HEALTH AUTHORITY GUIDELINES FOR SAMPLE REQUIREMENTS PER OREGON ADMINISTRATIVE RULES OAR 333-061-0335 AND OAR 333-061-0330 WHICH CAN BE FOUND [HERE](#)**

DEFINITIONS

- Finish Chlorine: Chlorine level of finished water being distributed
- Finish pH: pH level of finished water being distributed
- Finish Water Turbidity: Turbidity level of water being distributed
- pH: Power of hydrogen
- Raw Water Turbidity: Turbidity of untreated South Santiam River water pulled from water intake
- Turbidity: Cloudiness of the water