



<b>Historical Water Sample Data</b>
Week of March 21, 2024, through March 27, 2024

**Finish Chlorine**

Min (> 0.20 mg/L)*	Max (< 4.00 mg/L)*	Average (~ 1.00 mg/L)*
0.89	1.24	1.01

**Finish pH**

Min (> 7.00 pH)*	Max (< 9.00 pH)*	Average
7.62	8.10	7.71

**Raw Water Turbidity**

Min	Max	Average
6	14	8

**Finish Water Turbidity**

Min	Max (.100 NTU)*	Average
0.012	0.038	0.021

**\* THESE NUMBERS REPRESENT OREGON HEALTH AUTHORITY GUIDELINES FOR SAMPLE REQUIREMENTS PER OREGON ADMINISTRATIVE RULES OAR 333-061-0335 AND OAR 333-061-0330 WHICH CAN BE FOUND [HERE](#)**

**DEFINITIONS**

- Finish Chlorine: Chlorine level of finished water being distributed
- Finish pH: pH level of finished water being distributed
- Finish Water Turbidity: Turbidity level of water being distributed
- pH: Power of hydrogen
- Raw Water Turbidity: Turbidity of untreated South Santiam River water pulled from water intake
- Turbidity: Cloudiness of the water