



| |
|--|
| Historical Water Sample Data |
| Week of December 30, 2023, through January 2, 2024 |

Finish Chlorine

| Min (> 0.20 mg/L)* | Max (< 4.00 mg/L)* | Average (~ 1.00 mg/L)* |
|-----------------------|-----------------------|---------------------------|
| 0.88 | 1.29 | 1.10 |

Finish pH

| Min (> 7.00 pH)* | Max (< 9.00 pH)* | Average |
|---------------------|---------------------|---------|
| 7.71 | 7.85 | 7.80 |

Raw Water Turbidity

| Min | Max | Average |
|-----|-----|---------|
| 36 | 40 | 38 |

Finish Water Turbidity

| Min | Max (.100 NTU)* | Average |
|-------|--------------------|---------|
| 0.014 | 0.016 | 0.014 |

*** THESE NUMBERS REPRESENT OREGON HEALTH AUTHORITY GUIDELINES FOR SAMPLE REQUIREMENTS PER OREGON ADMINISTRATIVE RULES OAR 333-061-0335 AND OAR 333-061-0330 WHICH CAN BE FOUND [HERE](#)**

DEFINITIONS

- Finish Chlorine: Chlorine level of finished water being distributed
- Finish pH: pH level of finished water being distributed
- Finish Water Turbidity: Turbidity level of water being distributed
- pH: Power of hydrogen
- Raw Water Turbidity: Turbidity of untreated South Santiam River water pulled from water intake
- Turbidity: Cloudiness of the water